

شماره : یک

وضعیت

تاریخ : 88/7/20

بازنگری

ES/9000 (9121-742)

	فروردین	اردیبهشت	خرداد	تیر	مرداد	شهریور	مهر	آبان	آذر	دی	بهمن	اسفند
9121	S	S	D	S	S	F	D	S	S	S	D	F
37x5	f	f	f	D	f	f	F	D	f	f	f	D
34X0	f, V	f, D	f	f, V	g	f, D	f	f	f, V	F, D	F, f	f
3174	f	f	f	g	f	f	f	f	f	g	f	f
Printer	G	G	G	G	G	G	G	G	G	G	G	G

S = CPU visual checking (voltage . Error log, Fan, ...)

D = Diagnostic Test

F = Filter Cleaning

f = Fan checking

G = General cleaning

g = Ground checking

V = Voltage checking &amp; Adjusting